
2018 Water Quality Report

Lake Lawrence Mobile Home Park

PWS ID # 44130 9

H2O Management Services is pleased to present to you this year's Water Quality Report. This report is designed to inform you about the quality of your water and the services we deliver to you every day.

The Lake Lawrence MHP ownership has contracted with H2O Management Services since December 1, 2010 to provide professional management and operation of the system by qualified personnel. You will see H2O in and about the community as we perform routine preventative maintenance and repairs. Thank you for giving us the opportunity to serve your community.

Where does my water come from?

Your water at Lake Lawrence MHP comes from a ground water well, Well #2 (SO2), at a depth of 77 ft. It is located in a pumphouse in the common area in the middle of park. Well #1 (SO1) has been completely disconnected from the domestic water distribution main and is designated as a domestic water source only in cases of emergency. Well #1 is also used in the park for irrigation purposes.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. **Microbial contaminants**, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. **Inorganic contaminants**, such as salts and metals, can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. **Radioactive contaminants** can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, the Washington State Department of Health and the U. S. Environmental Protection Agency prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and the Washington State Department of Agriculture regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Variances and Exemptions (Waivers)

An assessment of Lake Lawrence MHP water system source water was done by the Department of Health to determine the susceptibility of your sources to contaminants. This is important because the assessment determined that the susceptibility of your water to contaminants is high. Based on this determination and past sampling results, the Department of Health granted Lake Lawrence MHP water system waivers which allowed reduced testing for Inorganic Chemicals (IOC) through 2018, and a full waiver from testing for Volatile Organic Contaminants (VOC) through 2016. New waivers will be applied for

when offered by the Washington State Department of Health.

SWAP data for your PWS is online at <https://fortress.wa.gov/doh/eh/dw/swap/maps/>

Source protection information

Source Water Assessment Program (SWAP) data is available for all community PWSs in Washington.

If you don't have access to the Web, we encourage you to use the Internet service available through the public library system.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year January 1 thru December 31, 2018. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Contaminants	MCL	MCLG or AL:	Your Water	# Samples Exceeding MCL/AL	Sample Date	Violation or Exceeds AL	Typical Source
Inorganic Contaminants							
Nitrate [measured as Nitrogen] (ppm))	10	10	5.4	0	11/15/2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Copper - action level at consumer taps (ppm) 90 th Percentile Results	NA	1.3 AL	.06	0 of 5	12/16/2016	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb) 90 th Percentile Results	NA	15	.0018	0 of 5	12/16/2016	No	Corrosion of household plumbing systems; Erosion of natural deposits
State Regulated Contaminants	SRL		Your Water	#Samples Exceeding SRL	Sample Date		Typical Source
Sodium (ppm)	5		8	1	3/30/10		Naturally occurring in the environment
Hardness (ppm)	10		69	1	3/30/10		Naturally occurring in the environment
Turbidity (NTU)	.1		.2	1	3/30/10		Soil Run Off
**Unregulated contaminants monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.							

Unit Descriptions

ppm: parts per million, or milligrams per liter (mg/L)

ppb: parts per billion, or micrograms per liter (ug/L)

NA: Not Applicable

NTU: Nephelometric Turbidity Units (water clarity)

Important Drinking Water Definitions

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

SRL: State Reporting Level. Secondary contaminants are those for which EPA has not established drinking water standards. The purpose of the secondary contaminant monitoring is to help EPA determine their occurrence in drinking water and potential need for future regulation.

Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Lead & Copper 90th Percentile: Out of every 10 homes sampled, 9 were at or below this level.

Este informe contiene informacion importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda. alguien que lo entienda. (English translation: This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

About Lead in Drinking Water If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lake Lawrence MHP is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791).or at <http://www.epa.gov/safewater/lead>.

Additional information for Nitrate

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Water Use Efficiency Report (WUE)

On August 16, 2011, an open meeting was held to give the public an opportunity to comment on Lake Lawrence MHP water system's proposed WUE goal as follows: To reduce summer water consumption by one percent per year over the next six years. We plan to accomplish this goal by: Public outreach; making available water saving devices; and utilizing conservation rates. No public comment was received as a result of the open meeting. You can help meet the 2017 summer water savings WUE goal of 1% savings system-wide by following these simple guidelines.

Car Washing

- Use a shut-off nozzle on your hose that can be adjusted down to a fine spray, so that water flows only as needed. Check hose connectors to make sure plastic or rubber washers are in place to prevent leaks.
- Consider using a commercial car wash that recycles water.
- Wash your car on the lawn, and you'll water your lawn at the same time.

Lawn Care

- More than 50 percent of residential irrigation water is lost due to evaporation, runoff, over watering, or improper system design/installation/maintenance.
- Don't over water your lawn. Lawns only need 1 inch of water per week. Buy a rain gauge so that you can better determine when to water.
- Water the lawn or garden early in the morning during the coolest part of the day. Consider installing an automatic timer. Don't forget to adjust your watering schedule, as days get longer or shorter.
- Raise your lawn mower cutting height—longer grass blades help shade each other, reduce evaporation, and inhibit weed growth.
- Use a broom or blower instead of a hose to clean leaves and other debris from your driveway or sidewalk.
- Don't leave sprinklers or hoses unattended. Set a kitchen timer when watering your lawn or garden to remind you when to stop. A running hose can discharge up to 10 gallons a minute.
- Adjust sprinklers so only your lawn is watered and not the house, sidewalk, or street.
- To water sloping lawns, apply water for 5 minutes and then repeat 2-3 times.
- If water runs off your lawn easily, split your watering time into shorter periods to allow for better absorption.

- Don't water your lawn on windy days when most of the water blows away or evaporates.
- Use sprinklers for larger areas of grass. Water small patches by hand to avoid waste.
- Let your lawn go dormant during the summer. Dormant grass only needs to be watered every 3 weeks or less if it rains.

If you wish to learn more about your water utility, plan to attend community meetings as they are scheduled by your local water association.

H2o Management Services Inc. is now on line. In the future, all CCR reports will be on the website. Look for them at the end of June of each year. Our website is h2omanagementservicesinc.com. When typing the URL be sure to use the letter "o" and not the number zero.

**If you have any questions about your water utility, please contact:
H2O Management Services Inc., PO Box 2026, Shelton, WA 98584
Website: h2omanagementservicesinc.com
Phone: 360-427-0654 Email: h2omgtsvs@gmail.com
Online: <http://www.doh.wa.gov/ehp/dw/>**